



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
RURAL DRINKING WATER & SANITATION DIVISION, MYSURU
Mysuru District Water Quality Testing Laboratory, Room No. 05, Zilla Panchayath
Premises, Near Law Court, Chamarajapuram Mohalla, Lakshmiapuram,
Mysuru - 570005. e-mail: rdwsd.wqmisp.mysore@gmail.com

TEST REPORT

Address of the sampling location/Name & address of the customer if any : Location : Dharsh school of Excellence Hanur town , M.M.Hills road Hanur taluk Chamarajanagar District		Report Date:16/04/2025			
		Report Number: MYS25DW0006			
		Reference: Test Request Form			
		Sample receipt date: 16/04/2025			
		Sample code : MYS25DW0006			
		Date of Sample collection: 16/04/2025			
		Analysis start date: 16/04/2025			
Sample Particulars: Drinking water -WPP Filter water		Sample collection protocol: RDWSD/WQMSP/SOP/23			
		Sample Quantity: 1Liter			
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless Liquid					
1.	pH Value @ 25.1°C	7.2	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, µS/cm@ 25.1°C	117	-	-	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):2018
4.	Colour, Hazen Units	1	5	15	IS 3025 (Part-4) :2021 Platinum Cobalt(Visual Comparison Method)
5.	Turbidity, NTU	0.5	1	5	IS 3025 (Part-10) : 2023
6.	Total Dissolved Solids@180°C, mg/l	72	500	2000	IS 3025 (Part-16) : 2023
7.	Alkalinity as CaCO ₃ , mg/l	36.54	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO ₃ , mg/l	36.39	200	600	IS 3025 (Part-21) : 2009(5 EDTA method)
9.	Calcium as Ca, mg/l	6.48	75	200	IS 3025 (Part-40) : 2024(5 EDTA Titrimetric method)
10.	Magnesium as Mg, mg/l	4.91	30	100	IS 3025 (Part-46) : 2023(6 Volumetric analysis using EDTA)
11.	Chloride as Cl, mg/l	10.00	250	1000	IS 3025 (Part-32) : 1988(Argentometric method)
12.	Sulphate as SO ₄ , mg/l	<1.00	200	400	IS 3025 (Part-24) : 2022(4 Turbidity method)
13.	Fluoride as F, mg/l	0.11	1	1.5	APHA 24 th Edition, 4500-F: D
14.	Nitrate as NO ₃ , mg/l	5.42	45	No relaxation	APHA 24 th Edition , 4500-NO3 -B
15.	Iron as Fe, mg/l	0.06	1	No relaxation	IS 3025 (Part-53) : 2024(6 1,10 Phenanthroline method)
Remarks: The above tested Physical & Chemical parameters conforms to the Acceptable limit of IS 10500:2012 Drinking water specification for the given sample only .					
Analysed by: Rashmishree R Junior Analyst <i>R</i>			Authorized Signatory: <i>Rashmishree R</i>		

RDWSD/WQMSP/TeR/01

Mysuru District Laboratory
Rural Drinking Water & Sanitation
Division, Mysuru

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
Secretary
- 4) Samples will be discarded after 15 days from the date of report generation.
Sri Srinivasa Trust
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/TeR/01.
No.302/148/AT, Bandahalli Road
Vinayaka Nagar, Hanur,
Chamarajanagar-571439

**** End of Report ****

Principal
Dharsh School of Excellence
Hanur Town, M.M.Hills Road
Hanur Taluk
Chamarajanagar District
Page 1 of 1



PROFORMA FOR SAFE DRINKING WATER CERTIFICATE

No. RDWSD/WQMSP/LAB/02

Dated: 16.04.2025

It is certified that from **Mysuru District Water Quality Testing Laboratory, Rural Drinking Water and Sanitation Department Mysuru, Government of Karnataka**, water sample tested on 16.04.2025 and on the basis of Water Test Report (Attached) bearing sample code **MYS25DW0006** dated **16.04.2025** certified that **Dharsh school of Excellence Hanur Town, M.M Hills Road Hanur Taluk Chamarajanagar District** has safe drinking water facilities for the students and members of staff of the institution.

Enclosure: Water Test Report

Name: *Rashmishree R*

Designation: *Junior Analyst*

Signature with Seal: *[Signature]*
Mysuru District Laboratory
Rural Drinking Water & Sanitation
Division, Mysuru

To,
Dharsh scholl of Excellence
Hanur Town
Hanur Taluk
Chamarajanagar District

[Signature]
Secretary,
Sri Srinivasa Trust,
No.302/148/A1, Bandahalli Road,
Vinayaka Nagar, Hanur,
Chamarajanagar-571439

[Signature]
Principal
Dharsh School of Excellence
Hanur Town, M.M.Hills Road
Hanur Taluk
Chamarajanagar District